

Log No. 14866

Permit No.

Basin

#4

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Green Const. Co. ADDRESS 501 East John Carson City, Nevada 89701

2. LOCATION 1/4 Sec. 6 T. 12 N/S R. 21 E. Douglas County
 PERMIT NO. LOT #67; FISH SPRINGS ESTATES

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown to yellow clay w/ 2% semi-rounded gravels to 1" diam. mixed.		0	4	4
Fine to coarse sand w/ semi-rounded gravels to 2" mixed. Tight.		4	25	21
Coarse sand w/ 5% silt & 5% gravels to 2" diam. Some water @ 35'		25	55	30
As above w/ smaller gravels & occasional yellow clay streak mixed		55	63	8
Coarse sand w/ semi-rounded gravels to 3/4" mixed. Water bearing		63	66	3
Sandy yellow clay		66	71	5

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 70 feet
 Casing record 0-70' X 65/80D
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>70</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type transit mix
 Depth of seal 47 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 X 2 1/2"
 From 60 feet to 70 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started 6-25-75, 19.....
 Date completed 6-26-75, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR BLOWN: 14GPM @ 68' depth</u>			

BAILER TEST

G.P.M.	Draw down..... feet hours
G.P.M.	Draw down..... feet hours
G.P.M.	Draw down..... feet hours

9. WATER LEVEL

Static water level 22 Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nevada

Nevada contractor's license number 9767

Nevada driller's license number 493

Signed W.L. McDonald

Date 28 June, 1975