DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14888 C
Permit No. 29202
Basin 162

1. OWNER Bob Rund ADDRESS Pahrump Nev.
No 5 well Basin

2. LOCATION SE ¼ SE ¼ Sec. 9 T. 20 N/S R. 53 E. Nye County
PERMIT NO. - 29202 - 29203

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4'
brown clay		4	45	41'
gravel	X	45	47	2'
Hard shale		47	53	6'
clay		53	67	14'
Shale		67	74	7'
clay		74	92	18'
soft clay	X	92	98	6'
brown clay		98	130	32'
soft clay	X	130	135	5'
Brown clay		135	154	19'
soft clay	X	154	163	9'
clay		163	180	17'
hard tough clay		180	194	14'
soft clay	X	194	202	8'
brown clay		202	256	54'
hard tough clay		256	242	6'
soft brown clay	X	262	271	9'
brown clay	X	271	356	85'
hard formation		356	361	5'
brown clay	X	361	402	31'
hard formation		402	410	8'
brown clay		410	442	32'
sandy clay	X	442	452	10'
brown clay		452	476	24'
clay with gravel		476	488	12'
hard lime		488	490	2'

(over)

Date started May 27, 19 75
Date completed June 26, 19 75

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
JUL 7 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. 20 Draw down 0 feet 0 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 550 feet
Casing record 260 12" casing 250 - 530 8" casing
Weight per foot 26 lbs Thickness 5/16"

Diameter		From		To	
12	inches	0	feet	260	feet
8	inches	250	feet	530	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from - 0 - feet to - 0 - feet

Perforations:
Type perforation torch cut
Size perforation 5/8" wide 12" long
From 80 feet to 260 feet
From 250 feet to 530 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface 40
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling
Address Box 807B Pahrump Nev
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg (on)
Date July 6, 1975

USE ADDITIONAL SHEETS IF NECESSARY

5471