

OFFICE USE ONLY
Log No. 14208
Permit No.
Basin Eagle Valley
134

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Vaughn Spofford ADDRESS 610 South Sutro Terrace
Carson City, Nevada 89701

2. LOCATION S 1/2 1/4 1/4 Sec. 32 T. 16N N/S R. 20 E Carson County
PERMIT NO. (610 South Sutro Terrace)

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	8	8
Green clay		8	66	58
Green clay w/ rock lenses		66	90	24
Green clay w/ black rock streaks		90	155	65
Grey to black rock w/ inconsistant fractured zones. Rock is hard to very hard. Water bearing		155	180	25
Black rock w/ some clay areas. Rock is hard in 2-4' streaks. Inconsistantly water bearing		180	203	23

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 191 feet
Casing record 0-191 X 6 5/8 OD
Weight per foot 12.89 Thickness 188

Diameter	From	To
10 inches	0 feet	55 feet
8 1/2 inches	55 feet	191 feet

Surface seal: Yes No Type transit mix
Depth of seal 52 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation factory mill slot
Size perforation 3/32 X 3"
From 151 feet to 191 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 7-18-75, 19_____
Date completed 7-22-75, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN: 10GPM @ 188' depth			
(well is capable of more water. Loosing air due to excessive amount of perms.)			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 135 Feet below land surface
Flow _____ G.P.M.
Water temperature 75 °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404; Sparks, Nevada
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed *W.L. McDonald*
Date 23 July, 1975