

OFFICE USE ONLY
 Log No. 14939
 Permit No.
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Michael Wade ADDRESS 13101 South Virginia Street
Reno, Nevada 89502

2. LOCATION Lot 1/4; Block 1/4 Sec. 32 T. 18N N/S R. 21 E Storey County
 PERMIT NO. Virginia City Highlands; 255 Adobe Road

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	3	3
Brown clay		3	23	20
Red clay		23	27	4
Red clay- lighter in color		27	52	5
Grey clay w/ some broken rock		52	75	23
Grey sand w/ broken grey rock		75	80	5
Hard to medium hard grey rock- fractured		80	90	10
Green rock w/ clay	X	90	132	42
Grey sandy clay- hard		132	165	33
Black rock w/ sandy clay		165	185	20
Hard grey rock		185	193	8
Hard black rock		193	220	27
Red rock- fractured & loose				
Some hard spots- possible water		220	295	75

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 275 feet
 Casing record 0-275' X 6 5/8OD
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>55</u> feet
<u>8 1/2</u> inches	<u>55</u> feet	<u>275</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type transit mix
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation factory mill slot
 Size perforation 3/32 X 3"
 From 189 feet to 275 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL

Static water level..... Feet below land surface.....
 Flow Ground level G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 493
 Signed [Signature]
 Date 30 July, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Test pumped @ 6GPM @ 240' depth

BAILER TEST

G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

AQUA DRILLING & WELL SERVICE, INC.

675 EDISON WAY
RENO, NEVADA 89502

Division of Water Resources
123 W. Nye Lane
Carson City, Nv 89710
Attn: Tom Gallagher

August 5, 1999

Re: Request for waiver of Nevada Revised Statutes for well plugging.

Dear Mr. Gallagher,

Aqua Drilling would like to apply for a waiver of the NRS 534.420 for well plugging. This waiver would be for the benefit of:


Wally Corey
2331 Grizzley Rd
Reno, Nv 89511

SW NE 32 18/21
APN 03-022-18

Per your well log #14799, there is no casing from 155'-203' and no perforated casing anywhere. The static water level has dropped from 90' to approximately 190' and is now only producing approximately 1 gallon per minute.

A hardship would be placed on Wally Corey by having to tear down his well/pump house to plug his well according to regulations, which is why Aqua is requesting a waiver. Aqua would like permission to run a tremie tube to the bottom of the well and pump neat cement from the bottom to the surface.

I look forward to hearing from you soon.

Sincerely,

Roger Thrall
President

