DIVISION OF WATER RESOURCES

28217

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15179
Permit No. 28217
Basin

1. OWNER Tony Santos ADDRESS P.O. Box 374
Winnemucca Nevada

2. LOCATION NW ¼ SW ¼ Sec. 26 T. 36 N/S R. 37 E. Humboldt County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil	No	0	4	4
Hard Sandy Clay	"	4	35	31
Hard Rocky Clay	"	35	107	72
Light Rocky Clay				
With small loose				
Rocky clay Streaks	yes	107	170	63

Date started July 21, 1975
Date completed Sept 23, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No Test			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 170 feet
Casing record 0 - 170
Weight per foot 22 Thickness 3/16

Diameter	From	To
10 inches	0 feet	170 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Mud
Depth of seal 20 ft. feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Mills
Size perforation 3/16 x 2"
From 170 feet to 100 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface 70 ft.
Flow None G.P.M.
Water temperature 63 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name L.B.J. Drilling & Pump Co
Address P.O. Box 902 Winnemucca
Nevada contractor's license number 9605
Nevada driller's license number 637
Signed Joe Bossin Jr.
Date Oct 26 1975

USE ADDITIONAL SHEETS IF NECESSARY

5471