DIVISION OF WATER RESOURCES

Paul R. Lewis + Patricia Lewis
~~Paul Lewis~~

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15213
Permit No.
Basin 220

1. OWNER ~~Paul R. Lewis~~ ADDRESS Glendale, Nev

2. LOCATION SW ¼ SW ¼ Sec. 1 T. 15 N/S R. 66 E. County
PERMIT NO. [redacted]

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☒ Irrigation ☐ Test ☐	Cable ☐ Rotary ☒
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0	6	6
Clay		6	18	12
Course Sand		18	40	22
Sand & Gravel		40	56	16
Course Sand & Gravel		56	80	24
Sand & Gravel	X	80	90	10
Clay		90	95	5
Gravel &	X	95	125	30

RECEIVED
AUG 14 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 3-13, 1975
Date completed 5-15, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Compressing			4 Hours
Approx 100 H.P.M.			
80 Foot			

BAILER TEST

G.P.M. 20 Draw down 60 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 125 feet
Casing record
Weight per foot Thickness 188

Diameter	From	
6 inches	0 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Welded
Depth of seal 0-100 Cemented feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 125 feet

Perforations:
Type perforation Slotted
Size perforation ¼ X 6
From 100 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name B & B Drilling
Address Beaver Utah
Nevada contractor's license number 7381
Nevada driller's license number 739
Signed Ronald Bradshaw
Date ~~July~~ June 25, 75

USE ADDITIONAL SHEETS IF NECESSARY