

Log No. 15237
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Millard Realty & Const. ADDRESS 224 South Carson St.
Carson City, Nevada 89701

2. LOCATION 1/4 SW 1/4 Sec. 22 T. 15 N/S R. 20 E Carson City County
PERMIT NO. Lot # 24 Carson View Estates

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| Sandy clay | | 0 | 55 | 55 |
| Decomposed granite | x | 55 | 70 | 15 |
| Sandy clay | | 70 | 78 | 8 |
| Decomposed granite | x | 78 | 90 | 12 |
| Sandy clay | | 90 | 112 | 22 |
| Decomposed granite | x | 112 | 118 | 6 |
| Sandy clay | | 118 | 122 | 4 |
| Decomposed granite | x | 122 | 127 | 5 |
| Sandy clay | | 127 | 128 | 1 |

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 128 feet
Casing record.....
Weight per foot 12.89 Thickness 1.88

| Diameter | From | To |
|---------------------|---------------|-----------------|
| <u>6 5/8</u> inches | <u>0</u> feet | <u>129</u> feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes No Type Neet Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from feet to feet

Perforations:
Type perforation Mill Slot
Size perforation 3/32" x 3"
From 104 feet to 124 feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 45
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. M. Blain Drilling
Address P. O. Box 353 Dayton, Nev.
Nevada contractor's license number 10950
Nevada driller's license number 757
Signed Charles Rehe
Date Nov 24 1975

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
G.P.M. 20 Draw down 40 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours