

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Lance Rose ADDRESS Smith Hill

2. LOCATION SE 1/4 NW 1/4 Sec 4 T. 10 N. R. 24 E. Lyon County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel, rock + dirt	No	0	10	10
Brown dirt	No	10	47	37
Yellow clay	No	47	69	22
Gravel	Yes	69	77	8
Clay and gravel stratas	No	77	110	33
Yellow clay and fine sand	No	110	162	52
Gravel and sand	Yes	162	184	22

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 184 feet
 Casing record 184 Ft.
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>184</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Saw Slot
 Size perforation 1/8" x 4"
 From 168 feet to 178 feet
 From _____ feet to _____ feet

Date started 11-13, 19 75
 Date completed 11-22, 19 75

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3 Hsp</u>	<u>38</u>	<u>87</u>	<u>3</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 7.3 Feet below land surface 68
 Flow _____ G.P.M.
 Water temperature 55 ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Co
 Address Box 92, Smith, Nev. 89430
 Nevada contractor's license number 12272
 Nevada driller's license number 718
 Signed Edmund Miller
 Date 11-26-75

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours