

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER U.S. B.I.A. / CHILTON ENG. ADDRESS 421 COURT ST. ELKO, NV  
Sheep Creek Recreation Site #1  
 2. LOCATION 1/4 SE 1/4 Sec 28 T. 46 N/S R. 51 E. ELKO County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOIL		0	1	1
ALLUVIUM		1	30	29
SANDSTONE	vvv	30	73	43
CLAY		73	75	2
T. D. 75				

8. WELL CONSTRUCTION  
 Diameter hole 1.0 inches Total depth 75 feet  
 Casing record 76 ft x 6 3/8  
 Weight per foot 17.02 Thickness 2.50  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT & SAND  
 Depth of seal 5.5 feet  
 Gravel packed: Yes  No   
 Gravel packed from 5.5 feet to 7.5 feet  
 Perforations:  
 Type perforation 1/8 x 3" x 12/PL  
 Size perforation M.I.I. slots  
 From 5.5 feet to 7.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 1.2 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature Cold ° F. Quality Good

Date started 11/21, 1975  
 Date completed 11/24, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Muth Drilling Co. JACK P. MUTH  
 Address 203 Pine Street Elko, Nevada 89801  
 Nevada contractor's license number 10819  
 Nevada driller's license number 632  
 Signed James V. Muth  
 Date 12/15/75

BAILER TEST  
 G.P.M. 4.20 Draw down 5 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours