DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15422
Permit No.
Basin

1. OWNER Catholic Church ADDRESS Carson City, NV 89701

2. LOCATION SE ¼ SW ¼ Sec. 25 T. 15 N/S R 20 E. CC County
PERMIT NO. Corner Center St Stewart School Property

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		95	106	11
Sand		106	110	4
Sandy Clay		110	114	4
Sand		114	134	20
Sandy Clay		134	135	1

6 5/8 (Liner)

Date started 11-24-75, 19
Date completed 11-26-75, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 5 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 135 feet
Casing record
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	135 feet
8 5/8 inches	0 feet	95 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 6 5/8 (115 - feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 40
Flow G.P.M.
Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blain
Address Box 353 Dayton NV 89403
Nevada contractor's license number 10950
Nevada driller's license number 757
Signed Chuck Rohe
Date 3/15/76

USE ADDITIONAL SHEETS IF NECESSARY

5471