DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. [illegible]
Permit No. [illegible]
Basin [illegible]

1. OWNER James Caples ADDRESS Box 2484 Dayton, Nev 89403

2. LOCATION ¼ ¼ Sec. 20 T. 17 N/S R. 22 E. Storey County
PERMIT NO. Lot 47 Unit #3 Mark Twain Estates Sutro Springs + Martinsts

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Dirt		0	6	6
Br Dirt & D.G		6	80	74
Br Clay		80	88	8
D.G. & Sand Clay		88	128	40
Br Gravel	✓	128	152	24
Blue Clay		152	153	1
Black Sand & Gravel		153	160	7

Date started 2-14-76, 19
Date completed 2-17-76, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 20 feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
12" = 50'
Diameter hole 110' = 8" inches Total depth 160 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness 188

Diameter	From	To
8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 136 feet to 156 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 124 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W M Blain
Address Box 353 Dayton Nev 89403
Nevada contractor's license number 10950
Nevada driller's license number 717
Signed Warren Labrum
Date 3/15/76

USE ADDITIONAL SHEETS IF NECESSARY