DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 15463
Permit No.
Basin

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER Wallace Johnson ADDRESS Robinson Lane Fallon, Nv. 89406

2. LOCATION NW ¼ NE ¼ Sec. 19 T. 19 N/S R. 28 E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fine sand water | | 0 | 14' | |
| Clay | | 14' | 25' | |
| sandstone | | 25' | 28' | |
| Clay | | 28' | 30' | |
| Coarse sand | | 30' | 37' | |
| Course sand-Bottom | | 37' | 41' | |

Date started 4-2-, 1976
Date completed 4-6-, 1976

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 3600 | 10' | 1 hr. |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 41' feet
Casing record Steel
Weight per foot Thickness

| Diameter | From | To |
|---|---|---|
| 8" inches | 0 feet | 37 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type
Depth of seal 12' feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From 37 feet to 41 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 4' 8" Feet below land surface
Flow good G.P.M.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bert Van Komen
Address 845 Mc Lean Street
Nevada contractor's license number 6927A
Nevada driller's license number 609
Signed Bert Van Komen
Date 4-7-76

USE ADDITIONAL SHEETS IF NECESSARY

5471