DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15471
Permit No.
Basin

1. OWNER ROBERT AVERY ADDRESS WINNEMUCCA NEV.

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 39 N/S R. 38 E. HUMBOLDT County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK SOIL		0	11	11
DRY BROKEN GRAVEL SOME CLAY		11	23	12
CLAY + GRAVEL		23	90	67
SOFT CLAY		90	96	6
HARD CLAY SOME GRAVEL		96	111	16
FINE GRAVEL + SAND	1ST	111	119	8
GRAVEL CLAY SEAMS	2ND	119	140	21
CLEAN FINE GRAVEL	3RD	140	147	7

Date started MARCH 16, 1976
Date completed MARCH 19, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
WELL IS EQUIPPED WITH 1½ HP SUB PUMP SET TO 147' DELIVERS 20 GPM.			

BAILER TEST
G.P.M. 30 Draw down 15 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 147 feet
Casing record SET TO BOTTOM
Weight per foot 20# Thickness ¼

Diameter	From	To
6 inches	0 feet	147 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation TORCH SLOTS
Size perforation 1/8 X 3" 4 ROWS
From 120 feet to 147 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 111 Feet below land surface 88
Flow G.P.M.
Water temperature 47 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dave McNinch
Address Box 585 Winnemucca Nev.
Nevada contractor's license number 5437
Nevada driller's license number 219
Signed Dave McNinch
Date April 10, 1976

USE ADDITIONAL SHEETS IF NECESSARY

5471