

OFFICE USE ONLY
Log No. 15980
Permit No. _____
Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Blue Tag Farms, Inc. ADDRESS Box 246
Ketchum, Idaho 83340

2. LOCATION SW 1/4 NW 1/4 Sec. 2 T. 33N N/S R. 49 E County _____
PERMIT NO. _____

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other rev.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	4	
Coarse sand & gravel		4	24	
Brown sandy clay		24	27	
Coarse sand & gravel w/ layers of clay		27	42	
Coarse sand & gravel		42	61	
Brown sandy clay w/layers of gravel		61	63	
Coarse sand & gravel		63	82	
Brown sandy clay & gravel		82	105	
Coarse sand & gravel		105	108	
Brown sandy clay w/layers of clay		108	121	
Brown sandy clay		121	208	
Coarse sand		208	219	
Sandy grey clay		219	234	
Layers of coarse sand & clay		234	240	
Sandy grey clay		240	247	
Coarse sand & gravel		247	262	
Clay & gravel		262	263	
Coarse sand & gravel		263	280	
Layers of brown clay & gravel		280	285	
Coarse sand & gravel		285	290	
Layers of clay and gravel		290	295	
Coarse sand & gravel		295	318	
Coarse sand, gravel & rock		318	354	

(con't on back of page)

Date started 4-12- 1976
Date completed 4-13- 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	2800	140'	
	2400	129'	3 min, rec.
	2000	114'6"	
	1700	108'	55'
	1500	97'	

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter hole 26 inches Total depth 500 feet
Casing record _____
Weight per foot 42 lbs. Thickness 1/2"

Diameter	From	To
<u>16</u> inches	<u>+2</u> feet	<u>500</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
Depth of seal _____ feet
Gravel packed: Yes No
Gravel packed from 0 feet to 500 feet

Perforations:
Type perforation louvered
Size perforation 3/32
From 212 feet to 500 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 40 Feet below land surface
Flow _____ G.P.M.
Water temperature _____ ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.B. Barrow

Address P.O. Box 888 Woodland, Ca. 95695

Nevada contractor's license number 12852

Nevada driller's license number 793

Signed A.B. Barrow

Date 4/15/76

Brown sandy clay	354	357
Coarse sand & gravel	357	428
Layers of clay & gravel	428	432
Gravel & rock	432	440
Clay & gravel	440	445
Coarse sand & gravel	445	462
Brown sandy clay	462	465
Coarse sand & gravel	465	469
Brown sandy clay	469	472
Clay & gravel	472	478
Coarse sand & gravel	478	490
Layers of clay & gravel	490	491
Coarse sand, gravel w/layers of clay	491	500

1073 APR 19 AM 10 50