

Log No. 15546
 Permit No.
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER NEVADA PAVINE, INC ADDRESS 1900 Glendale Rd. Sparks, Nevada
 2. LOCATION SW 1/4 SW 1/4 Sec 28 T. 18N N/S R. 34 E CHURCHILL (?) County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand mixed w/ some clay		0	5	5
Fine to coarse sand mixed w/ gravels to 1" diameter		5	15	10
Brown sandy clay w/ some gravels mixed		15	20	5
Sand w/ gravels to 1" diameter mixed		20	24	4
Brown clay w/ some gravels mixed		24	90	66
Brown clay w/ sharp gravels or broken rock to 1/2" diameter mixed-sometimes loose		90	210	120
Red to green gravels to 1" diameter (or broken rock)- loose		210	250	40
As above but blue to red- probably rock or weathered/decomposed material		250	270	20
Brown sand w/ gravels-tight		270	290	20
Blueish rock- broken		290	310	20
Blue to brown to green rokk like material-				

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 475 feet
 Casing record 0-262 X 8 5/8; 255-405X6 5/8
 Weight per foot 16.90; 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>262</u> feet
<u>8 1/2</u> inches	<u>262</u> feet	<u>405</u> feet
<u>6 1/4</u> inches	<u>405</u> feet	<u>482</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type.....
 Depth of seal none feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation factory mill slot
 Size perforation 3/32 X 2 1/2"
 From 265 feet to 405 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started....., 19.....
 Date completed....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 212 Feet below land surface
 Flow..... G.P.M.
 Water temperature 79 °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 817

BAILER TEST
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

Signed Frank Padilla by: W.L. McDonald
 Date 3 May, 1976

