

OFFICE USE ONLY  
 Log No. 15581  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER ROY D THOMSEN ADDRESS 48 E 4TH W Winnemucca

2. LOCATION 1/4 Sec 25 T. 35 N/S R. 37 E. Humboldt County  
 PERMIT NO. PET BENTY ROAD

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>CEMENTED LEE GRAVEL</del>		0	73	73
<del>GRAVEL</del>	YES	73	75	2 FT
<del>HARD CLAYS</del>		75	94	19 FT
<del>SAND GRAVEL</del>		94	150	56
<del>CLAY</del>		150	152	2

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 152 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 3/16  
 Diameter 8 inches From 0 feet To 152 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 52 FT feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation SAWN  
 Size perforation 1/8  
 From 112 feet to 152 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 79 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

Date started APRIL 15, 1976  
 Date completed MAY 8, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>37</u>	<u>2</u>	<u>8</u>

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WALTER D VETTER  
 Address Box 347 Winnemucca NV  
 Nevada contractor's license number 7600  
 Nevada driller's license number 504  
 Signed Walter D Vetter  
 Date 5-20-76