

OFFICE USE ONLY  
 Log No. 15606  
 Permit No. ....  
 Basin. ....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr. Ralph Grigg ADDRESS 890 Rice Rd.

2. LOCATION SW 1/4 NW 1/4 Sec. 19 T. 19 N/S R. 29 E. Churchill County  
 PERMIT NO. ....

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	4	4
Clay (Soft)		4	12	8
Sand	✓	12	19	7
Clay		19	21	2
Sand	✓	21	28	7
Clay		28	—	—

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 28 feet  
 Casing record.....  
 Weight per foot..... Thickness 135  

Diameter	From	To
inches	<u>01</u> feet	<u>28</u> feet
inches	.....	.....

 Surface seal: Yes  No  Type Grout  
 Depth of seal 12 feet  
 Gravel packed: Yes  No   
 Gravel packed from 12 feet to 28 feet  
 Perforations:  
 Type perforation Saw Cut  
 Size perforation 3/16  
 From 15 feet to 27 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL  
 Static water level 22 Feet below land surface 6  
 Flow 1" G.P.M. 20  
 Water temperature Cold ° F. Quality Good

Date started Oct 3, 1975  
 Date completed Oct 13, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3000</u>	<u>20</u>	<u>4'</u>	<u>60</u>
.....	.....	.....	.....
.....	.....	.....	.....

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Paul N. Pflimlin  
 Address 7007 Curry Rd.  
 Nevada contractor's license number 10655  
 Nevada driller's license number 768  
 Signed Paul N. Pflimlin  
 Date Nov 9, 1975

BAILER TEST  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours