

OFFICE USE ONLY
Log No. 15608
Permit No.
Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Chuck Wadsworth ADDRESS 2812 StarK Lane

2. LOCATION NE 1/4 SE 1/4 Sec. 33 T. 19 N/S R. 29 E. Churchill County
PERMIT NO.

3. TYPE OF WORK: New Well Recondition Deepen Other
4. PROPOSED USE: Domestic Irrigation Test Municipal Industrial Stock
5. TYPE WELL: Cable Rotary Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|----|------------|
| Top Soil | | 0 | 5 | 5 |
| Clay | | 5 | 11 | 6 |
| Sand | ✓ | 6 | 29 | 23 |
| Clay | | 29 | - | |

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 29 feet
Casing record
Weight per foot
Diameter inches From To
0.1 feet 29 feet
Surface seal: Yes No Type Grout
Depth of seal 9 feet
Gravel packed: Yes No
Gravel packed from 9 feet to 29 feet
Perforations:
Type perforation saw cut
Size perforation 3/16
From 1.5 feet to 27 feet

9. WATER LEVEL
Static water level 23 Feet below land surface 6
Flow 1 1/4 G.P.M. 30
Water temperature Cold ° F. Quality Good

Date started Dec 20, 1975
Date completed Dec 25, 1975

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------|-----------|-----------|------------------|
| <u>3000</u> | <u>30</u> | <u>7</u> | <u>14</u> |

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul N. Pflimlin
Address 2007 Curry Rd.
Nevada contractor's license number 10655
Nevada driller's license number 768
Signed Paul N. Pflimlin
Date Dec 25, 1975

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours