DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15716
Permit No.
Basin

1. OWNER G. DeLongchamps ADDRESS 16000 Callahan Road Formally Galena School

2. LOCATION ~~NE~~ SE ¼ ~~NW~~ SW ¼ Sec. ~~4~~ 2 T. 17 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☒
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		90	110	20
Brown Clay		110	116	6
Loose Gravel	Water	116	140	24

Blew Well with 220 Compressor
4 hr. Well Sand Free

Date started 9-14, 19 71
Date completed 9-20, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1½ HP	50	30	48

BAILER TEST
G.P.M. 40 Draw down 30 feet 8 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6⅝ inches Total depth 141 feet
Casing record Black Line pipe Welded
Weight per foot 12.89 Thickness .188

Diameter	From	To
6⅝ OD inches	90 feet	141 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 30 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Mills Knife
Size perforation ¼ x 2 - 4 Rows
From 90 feet to 110 feet
From 118 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 17 Feet below land surface
Flow None G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Smith-Pulati Inc.
Address 295-E 6th Ave Sparks
Nevada contractor's license number 6425A
Nevada driller's license number 207-208
Signed Claude Pulati
Date Copy 8-21-75

USE ADDITIONAL SHEETS IF NECESSARY

5471