

OFFICE USE ONLY
 Log No. 15793
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Andy Goulard ADDRESS _____

2. LOCATION 1/4 Sec. 33 T. 14 N/S R. 19 E Douglas County
 PERMIT NO. let. Cl. wads. St. SEWER U.P.C. Subdiv. 1010

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	4	4
Sand + Cobblers		4	26	22
Sand & DG		26	60	
Blockers	60-63	60	63	3
DG Sand		63	106	
Rock	95-106	106	107	1

8. WELL CONSTRUCTION
 Diameter hole 12" inches Total depth 103' feet
 Casing record _____
 Weight per foot _____ Thickness 188 wall

Diameter	From	To
<u>8 5/8</u> inches	<u>+1</u> feet	<u>107</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type _____
 Depth of seal 51' just feet
 Gravel packed: Yes No
 Gravel packed from 107' feet to 51' feet
 Perforations:
 Type perforation FACTORY
 Size perforation 3/32
 From 94 feet to 107 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 60 Feet below land surface
 Flow _____ G.P.M.
 Water temperature 60d ° F. Quality good

Date started June 20, 1976
 Date completed June 27, 1976

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name Enloe Drilling Co.
 Address 1000 Salmon
 Nevada contractor's license number 4329
 Nevada driller's license number 570
 Signed Chad L. Enloe
 Date 6/29/76

BAILER TEST
 G.P.M. 18 Draw down 14 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours