

OFFICE USE ONLY
 Log No. 15815
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER GEORGE A. BINNEY ADDRESS P.O. BOX 6, CRYSTAL BAY, NEVADA

Portion of:
 2. LOCATION NE 1/4 NE 1/4 Sec. 29 T. 43 N/S R. 19 E Washoe County
 PERMIT NO. 26997

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Brown Clay	110'	0	150	150
Sandy Brown Clay with streaks of small gravel		150	240	90
Sandy brown clay		240	300	60
Sandy brown clay		300	310	10
Sandy brown clay with streaks of sand and gravel.....		310	425	115
Gravel imbedded in brown clay...		425	490	65
Gray Shale		490	492	02
Sandy brown clay with streaks of gravel and sand.....		492	550	58
Sandy brown clay		550	593	43
Red clay with volcanic cinder rock (fine)...		593	625	32
Sandy brown clay		625	629	04

NOTE: THIS IS A REVISED LOG ON SAME WELL AS THE ONE FILED 5/20/76.

8. WELL CONSTRUCTION
 Diameter hole 16 inches Total depth 629 feet
 Casing record.....
 Weight per foot..... Thickness.....

Diameter	From	To	Thickness
<u>16</u> inches	<u>0</u> feet	<u>225</u> feet	<u>225</u> feet
<u>12</u> inches	<u>210</u> feet	<u>629</u> feet	<u>419</u> feet
..... inches feet feet feet
..... inches feet feet feet
..... inches feet feet feet
..... inches feet feet feet

 Surface seal: Yes No Type.....
 Depth of seal..... feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation factory & torch
 Size perforation 1/8 X 3
 From factory 105 feet to 225 feet
 From " 210 feet to 290 feet
 From torch 290 feet to 629 feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started May 4, 19 76
 Date completed August 18, 19 76

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

9. WATER LEVEL
 Static water level 70 Feet below land surface
 Flow..... G.P.M.
 Water temperature cold ° F. Quality.....

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Burroughs of Nevada
H. Wayne Burroughs
 Address 10310 Old Virginia City Road
Reno, Nevada 89511
 Nevada contractor's license number 5092
 Nevada driller's license number 759
 Signed Harold G. Dohben
 Date Sept. 7, 1976

