DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 15822
Permit No.
Basin

1. OWNER Gary Read Read ADDRESS 1205 Shady Oak Dr Ca, Nev

2. LOCATION NE ¼ NW ¼ Sec. 28 T. 15 N/S R. 20 E. Ca County
PERMIT NO. (Danni Dr)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay & Rock		0	105	105
Sand & Gravel	X	105	106	1
Sandy Clay & Rock		106	128	22
Sand & Gravel		128	134	6
Sandy Clay		134	147	13
Sand & Gravel		147	164	17
Sandy Clay		164	174	10
Sand & Gravel		174	180	6
Sandy Clay		180	188	8
Sand & Gravel		188	194	6
Sandy Clay		194	196	2

Date started 7-29-76, 19
Date completed 8-17-76, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 25 feet 1½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
12 11 50 14 8 7
Diameter hole 14 inches Total depth 196 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness .188

Diameter	From	To
8 inches	0 feet	196 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 172 feet to 192 feet
From (130 feet to 170) feet
From feet to feet
From Perf Mills Perforator feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 85
Flow G.P.M.
Water temperature Cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blain
Address Box 353 Dayton Nev 89403
Nevada contractor's license number 10950
Nevada driller's license number 757
Signed Charles Blain
Date 8/18/76

USE ADDITIONAL SHEETS IF NECESSARY

5471