

Sheet 1082

Log No. 15970
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Fred & Dorothy Schneider ADDRESS 425 Moran
Reno, NV 89502
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 34 T. 18N N/S R. 20 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red broken rock		0	15	15
Some Broken redish brown rock w/ a white chatty rock mixed in		15	25	10
Kind of a off white chalky white broken up rock		25	35	10
Reddish brown rock w/ some fine sands		35	50	15
Reddish brown rock		50	60	10
Rock is more red now no fine sand med. gravels		60	75	15
Reddish brown broken up rock		75	100	25
Had a small fracture		100	117	17
Small fracture still red-dish brown rock.		117	125	8
Brown broken shelly rock		125	130	5
Small fracture rock getting more reddish		130	135	5
Reddish brown and broken up		135	150	15
Got more gray some fine sand gray in color		150	153	3
Round gravels gray brown in color		153	175	22
Small fracture off white in color		175	183	8

Date started 11-3-76, 19____
 Date completed 11-4-76, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	8 GPM @	150' depth	
	14 GPM @	169' depth	

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 211 feet
 Casing record 0-211' x 6 5/8OD
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>211</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type transit mix
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 x 2 1/2"
 From 171 feet to 211 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed Tony Betita by W.L. McDonald
 Date 11-5-76

Sheet 2532

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No.
Permit No.
Basin

1. OWNER Fred & Dorothy Schneider ADDRESS 425 Moran Reno, NV 89502

2. LOCATION 1/4 1/4 Sec T N/S R E County PERMIT NO.

3. TYPE OF WORK: New Well, Recondition, Deepen, Other. 4. PROPOSED USE: Domestic, Municipal, Irrigation, Industrial, Test, Stock. 5. TYPE WELL: Cable, Rotary, Other.

LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Includes handwritten entries like 'Getting more small fractur formation little more white chalky mixed in 183 187 4'.

WELL CONSTRUCTION table with columns: Diameter, From, To, Thickness. Includes fields for Surface seal, Depth of seal, Gravel packed, and Perforations.

Date started, 19... Date completed, 19...

WELL TEST DATA table with columns: Pump RPM, G.P.M., Draw Down, After Hours Pump.

BAILER TEST table with columns: G.P.M., Draw down, feet, hours.

9. WATER LEVEL: Static water level, Flow, Water temperature.

10. DRILLERS CERTIFICATION: This well was drilled under my supervision and the report is true to the best of my knowledge. Name, Address, Nevada contractor's license number, Nevada driller's license number, Signed, Date.