

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr. William Curran ADDRESS Austin Hwy.

2. LOCATION SW 1/4 SE 1/4 Sec. 3 T. 18 N/S R. 29 E Churchill County  
 PERMIT NO.....

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand coarse	✓	2	5	3
Clay		5	6	1
Sand (Fine)	✓	6	14	8
Sand	✓	14	29	15
Clay		29	-	-

8. WELL CONSTRUCTION  
 Diameter hole..... 10 inches Total depth..... 29 feet  
 Casing record.....  
 Weight per foot..... Thickness.....  
 Diameter From To  
6 inches 01 feet 29 feet  
 ..... inches ..... feet ..... feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal..... 6 feet  
 Gravel packed: Yes  No   
 Gravel packed from..... 29 feet to..... 6 feet

Perforations:  
 Type perforation..... Saw Cut  
 Size perforation..... 3/16  
 From..... 15 feet to..... 27 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL  
 Static water level..... 25 Feet below land surface 4  
 Flow..... 1 1/2 G.P.M. 35  
 Water temperature..... Cold ° F. Quality..... Good

Date started..... Nov 22, 1976  
 Date completed..... Nov 24, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3000</u>	<u>35</u>	<u>6'</u>	<u>14 hrs</u>

BAILER TEST  
 G.P.M..... Draw down..... feet ..... hours  
 G.P.M..... Draw down..... feet ..... hours  
 G.P.M..... Draw down..... feet ..... hours

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Paul N. Pflimlin  
 Address 7007 Curry Rd.  
 Nevada contractor's license number 10655  
 Nevada driller's license number 768  
 Signed Paul N. Pflimlin  
 Date Nov 26, 1976