DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16115
Permit No. 30220
Basin

1. OWNER MELVIN & MARY STEVESON ADDRESS BOX 51
EAGLEVILLE, CALIFORNIA 96110

2. LOCATION S W ¼ S E ¼ Sec. 10 T. 36 N/S R. 18 E. WASHOE County
PERMIT NO. 30220

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
BROWN CLAY		2	16	14
SAND & GRAVEL		16	20	4
BROWN CLAY		20	35	15
GRAVEL & SMALL BOULDERS		35	60	25
BROWN CLAY		60	75	15
GRAVEL, SAND, & SM. BOULDERS		75	90	15
GRAVEL & BROWN CLAY		90	129	39
BROWN CLAY & SMALL BOULDERS		129	145	16
SAND & GRAVEL(BRN. & WHITE)		145	175	30
BROWN SANDY CLAY		175	235	60
BROWN SANDY CLAY & SOME GRAVEL		235	480	245
WHITE CLAY		480	530	50
RED CLAY		530	550	20
GREY CLAY(HARD)		550	560	10
BROWN & GREY CLAY		560	585	25
BLUE & BROWN CLAY & SOME SAND & GRAVEL		585	610	25

Date started NOVEMBER 29, 19 76
Date completed DECEMBER 22, 19 76

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	500	180'	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 20 inches Total depth 610 feet
Casing record 14" to 260' 8" to 610'
Weight per foot 14" ¼" wall - 8" 188 W Thickness

Diameter		From		To	
14"	inches	0	feet	260	feet
8"	inches	260	feet	610	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 610 feet

Perforations:
Type perforation FACTORY
Size perforation 1/8 x 3"
From 80 feet to 610 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80 Feet below land surface
Flow 500 G.P.M.
Water temperature cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BROWN BROTHERS WELL DRILLING
Address 215 JANI PL. SUN VALLEY, NEV. 89431
Nevada contractor's license number 13675
Nevada driller's license number 831
Signed Burbett W. Brown
Date JANUARY 3, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471