

OFFICE USE ONLY
 Log No. 16189
 Permit No. _____
 Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Frank W. Groves ADDRESS 1995 Lakeshore Dr.
Carson City, Nevada 89701

2. LOCATION NW $\frac{1}{4}$ $\frac{1}{4}$ Sec. 31 T. 17N N/S R. 20 E. Washoe County
 PERMIT NO. N/A

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	4'	4'
Decomposed Granite		4'	11'	7'
Hard Pan		11'	13'	2'
Fine Grey Sand		13'	25'	12'
First Water				
Fine Grey Sand		25'	55'	30'
Course Brown Sand		55'	70'	15'
More Water - Coarse				
Sand & Polished River				
Rock		70'	82'	12'
Course Sand & Gravel		82'	91'	9'
Dense Clay		91'	94'	3'

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 94 feet
 Casing record _____
 Weight per foot _____ Thickness 172

Diameter	From	To
12 inches	0 feet	50 feet
8 inches	0 feet	94 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 30 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 1/8"
 From 54 feet to 89 feet
 From _____ feet to _____ feet

Date started 15 January, 19 77
 Date completed 6 February, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	15	0	30

9. WATER LEVEL
 Static water level 17' Feet below land surface
 Flow est. 30 G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Russell C. Kabisch
 Address 2270 E. Lake Blvd.
Carson City, Nevada 89701
 Nevada contractor's license number _____
 Nevada driller's license number 867
 Signed Russell C. Kabisch
 Date 2-14-77

BAILER TEST
 G.P.M. 30 Draw down 4 feet 2 hours
 G.P.M. 60 Draw down 9 feet 4 hours
 G.P.M. _____ Draw down _____ feet _____ hours