STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. ~~16231~~ 16232
Permit No. 30463
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

HAROLD CALLIHAN

1. OWNER ~~JOHN BIONDI~~ ADDRESS 3475 MIRAMIK LAS VEGAS, NEV.

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 22 S N/S R. 61 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE SOIL & GRAVEL		0'	6'	6'
WHITE CLAY		6'	50'	44'
RED SAND & WATER	54'7"	50'	125'	75'
WHITE SANDY CLAY		125'	170'	45'
RED CLAY		170'	250'	80'

RECEIVED
JUL 7 1976
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started JUNE 12, 19 76
Date completed JUNE 19, 19 76

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth feet
Casing record 250 FEET OF 8" CASING
Weight per foot 20.16 Thickness 16 GAUGE

Diameter	From	To
8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation TORCH
Size perforation 3/16 INCH
From 109 feet to 244 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 54'7" Feet below land surface 54'7"
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BILL BLOOD
Address 3440 LAS VEGAS BLVD N.
Nevada contractor's license number 12264
Nevada driller's license number 798
Signed Bill Blood
Date 7/6/76

USE ADDITIONAL SHEETS IF NECESSARY

5471