DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. N 248
Permit No.
Basin

1. OWNER Cal Moore ADDRESS 10705 Whitehawk Dr. Reno, NV 89506

2. LOCATION ¼ ¼ Sec. 10 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. 7125 estate Lot 13; Steadfield estate Sub No. 1

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil & some brown clay		0	7	7
Brown clay & some brown sand		7	18	11
Brown clay & brown sand		18	64	46
Green blue granite water		64	103	38

Date started 1-11-77, 19
Date completed 1-12-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	24 GPM @ 100' depth		
	15 GPM @ 75' depth		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 103 feet
Casing record 0-103 x 6 5/80D
Weight per foot 12.89 Thickness .188

Diameter	From	To
10 inches	0 feet	50 feet
8½ inches	50 feet	103 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type transit mix
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 x 2½"
From 83 feet to 103 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 817
Signed Frank Padilla
Frank Padilla
Date 13 January, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER
1977 MAR 14 AM 11 10