DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1625
Permit No.
Basin

1. OWNER B.J. Poupeney ADDRESS 3055 Attridge Place Reno, NV 89503

2. LOCATION ¼ ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. Block 162 Lot 11, 3170 Indian; Golden Valley; Rno.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand & Brown clay		0	10	10
Brown decomposed granite sand		10	61	51
Corse decomposed granite sand w/ some water		61	110	49
Corse to fine sand & decomposed granite sand water		110	135	25

Date started 1-11-77, 19
Date completed 1-12-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	9 GPM @ 100' depth		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 135 feet
Casing record 0-135' x 6 5/8OD
Weight per foot 12.89 Thickness .188

Diameter	From	To
10 inches	0 feet	50 feet
8½ inches	50 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type transit mix
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory mill slot
Size perforation 1/8 x 2½"
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 65 Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 817
Signed Frank Padilla
Frank Padilla
Date 12 January, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1977 MAR 14 AM 11 10