

Log No. 16316  
Permit No.  
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER BEN McCullig ADDRESS 808 Pathway CC, NEV

2. LOCATION  $\frac{1}{4}$  Sec. 33 T. 15 N/S R. 20 E CC County  
PERMIT NO. 3800 Conti Dr - 50 Hillview

3. TYPE OF WORK		4. PROPOSED USE			5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dg</u>		<u>0</u>	<u>130</u>	<u>130</u>
<u>Whitish Clay Dg</u>	<u>X</u>	<u>130</u>	<u>160</u>	<u>30</u>
<u>Dg</u>		<u>160</u>	<u>180</u>	<u>20</u>

WELL CONSTRUCTION

Diameter hole 8 1/2 inches Total depth 180 feet

Casing record 8 3/8

Weight per foot 16.9 Thickness 18.8

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>180</u> feet

Surface seal: Yes  No  Type CONCRETE

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from 100 feet to 140 feet

Perforations:

Type perforation Facings

Size perforation 3 x 3/32

From 144 feet to 162 feet

Date started 3-7-77, 19.....  
Date completed 3-19-77, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 15 Draw down 15 feet 2 hours

G.P.M. Draw down feet hours

G.P.M. Draw down feet hours

9. WATER LEVEL

Static water level 125 Feet below land surface

Flow G.P.M.

Water temperature COLD ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blair

Address Box 353 Dayton, NV

Nevada contractor's license number 10950

Nevada driller's license number 757

Signed Charles Pike

Date 4/2/77