WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16360
Permit No.
Basin

1. OWNER GARY LUTZ ADDRESS 3300 Skyline, Apt. 176 Reno, NV 89500

Location: Wintergreen ~~Sub~~. #2, Lot 208

2. LOCATION ¼ ¼ Sec. 2 T. 17 N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & DG		0	70	70
Brn Clay w/gravel		70	105	35
Lava Sand & Silt	x	105	145	40
Lava Sand & Grvl	x	145	168	23

Date started March 14, 19 77
Date completed March 17, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole $8\frac{1}{2}$ inches Total depth 168 feet
Casing record 165 ft. 6-5/8"
Weight per foot Thickness .188

Diameter	From	To
6-5/8 inches	0 feet	165 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 75 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 75 feet to 105 feet

Perforations:
Type perforation Factory sawed slots
Size perforation $3/32 \times 2\frac{1}{2} \times 6$ slots around
From 125 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Appr. 67 Feet below land surface
Flow 25 G.P.M. w/air
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Address P. O. Box 347 Newcastle, CA 95658

Nevada contractor's license number 8937

Nevada driller's license number 471

Signed Wayne Dedman

Date March 24, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471