



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Green Construction ADDRESS 502 E. John
Carson City, NV 89701

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 30 T. 17N N/S R. 20 E. Washoe County
 PERMIT NO. Lot 27 Block 0 on Gander (4305.)

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Top soil		0	10	10
Brown clay sand		10	15	5
15 % coarse gravel & brown broken rock		15	25	10
20% coarse gravels brown broken rock 55% brown clay		25	35	10
Brown cemented sand med to fine		35	50	15
Brown clay-light brown cemented sand		50	65	15
Brown clay light brown cemented sands		65	75	10
Brown fine sandy clay		75	100	25
Fine to coarse sand less clay (cemented)		100	125	25
Fine to med sand yellow clay		125	135	10
Fine to coarse SAND cemented		135	150	15
Fine to coarse sand cemented med hard		150	160	10

8. WELL CONSTRUCTION

Diameter hole.....6.....inches Total depth.....160.....feet
 Casing record.....0 - 160' x 6.5/800
 Weight per foot.....12.89.....Thickness......188

Diameter	From	To
10 inches	0 feet	50 feet
8 1/2 inches	50 feet	160 feet
.....inchesfeetfeet

Surface seal: Yes No Type transit mix
 Depth of seal.....50.....feet
 Gravel packed: Yes No
 Gravel packed from.....feet to.....feet

Perforations:
 Type perforation.....factory mill slot
 Size perforation.....1/8 x 2 1/2"
 From.....140.....feet to.....160.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Date started.....4-21-77....., 19.....
 Date completed.....4-25-77....., 19.....

7. WELL TEST DATA			
Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	5 GPM @	135' depth	

9. WATER LEVEL

Static water level.....70.....Feet below land surface.....
 Flow.....G.P.M.....
 Water temperature.....cold° F. Quality.....not tested.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name.....W.L. McDonald & Co.....
 Address.....P.O. Box 404; Sparks, NV 89431.....
 Nevada contractor's license number.....9767.....
 Nevada driller's license number.....805.....
 Signed.....*Tony Betita by W.L. McDonald*
 Date.....27 April, 1977.....

BAILER TEST			
G.P.M.	Draw down	feet	hours