CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16409
Permit No.
Basin

1. OWNER Cheryl McKay ADDRESS 3504 Sun Cloud Circle

2. LOCATION SW ¼ SE ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Some decomposed granite sand w/ brown clay li		0	3	3
Light reddish sandy rock & clay		3	25	22
Reddish sandy rock w/ brown clays		25	50	25
White sandy rock w/ brown clay		50	100	50
White rock from 75' then brown-brown clay w/ fine sand		100	110	10
Gray rock w/ some brown rock mixed in-some clay		110	125	15
Gray rock w/ water(granite) about 10 to 12 GPM- in consistantly water bearing		125	170	45

Date started 4-11-77, 19
Date completed 4-11-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	12GPM @ 150' depth		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 170 ft
Casing record 0-170 x 6 5/8
Weight per foot Thickness

Diameter	From	To
16 inches	0 feet	50 feet
8½ inches	50 feet	170 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type transit mix
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory mill slot
Size perforation 1/8 x 2½"
From 146 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 805
Signed Tony Betita by W.L. McDonald
Tony Betita by: W.L. McDonald
Date April 12, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471

RECEIVED
03 AUG 11 PM 12:40
STATE ENGINEERS OFFICE

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 16409
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Cheryl McKay ADDRESS 3504 Sun Cloud Circle

2. LOCATION ¼ ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Some decomposed granite sand w/ brown clay		0	3	3
Light reddish sandy rock & clay		3	25	22
Reddish sandy rock w/ brown clays		25	50	25
White sandy rock w/ brown clay		50	100	50
White rock from 75' then brown-brown clay w/ fine sand		100	110	10
Gray rock w/ some brown rock mixed in-some clay		110	125	15
Gray rock w/ water(granite) about 10 to 12 GPM- in consistantly water bearing		125	170	45

Date started 4-11-77, 19
Date completed 4-11-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	12GPM @ 150' depth		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 170 feet
Casing record 0-170 x 6 5/8
Weight per foot Thickness

Diameter	From	To
10 inches	0 feet	50 feet
3½ inches	50 feet	170 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type transit mix
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory mill slot
Size perforation 1/8 x 2½"
From 146 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 805
Signed Tony Betita by W.L. McDonald
Tony Betita by: W.L. McDonald
Date April 12, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1977 MAY 9 AM 10 48