



OFFICE USE ONLY
Log No. 16431
Permit No.
Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER George Prutzman ADDRESS 7675 Lakeside Drive

2. LOCATION 1/4 1/4 Sec. 35 T. 19 N 15 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & Clay		0	45	45
Sand Stone & "		45	53	8
Clay & Rocky		53	72	19
Sand & gravel	1 st.	72	88	16
Clay & rocks		88	100	12
Sandy clay (brn.)		100	120	20
Sandy " White	2 nd.	120	130	10
Brown Clay		130	140	10

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record.....
Weight per foot 16 lbs. Thickness 188 wall

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>140</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement
Depth of seal 0 to 50 feet
Gravel packed: Yes No
Gravel packed from 60 feet to 140 feet

Perforations:
Type perforation Factory
Size perforation 1/16
From 100 feet to 140 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

9. WATER LEVEL
Static water level 45 Feet below land surface
Flow 22 G.P.M.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 4 - 11 - 77
Date completed 4 - 28 - 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name American Drilling Company
Address 83 Frontage Rd. Dayton, Nevada 89403
Nevada contractor's license number 12911
Nevada driller's license number 431

BAILER TEST
G.P.M. 22 Draw down 75 feet 4 hours
G.P.M. Draw down..... feet hours
G.P.M. Draw down..... feet hours

Signed [Signature]
Date April 28, 1977