



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Ron Blehm ADDRESS Box 119 Eureka, Nev. 89316

2. LOCATION NE 1/4 NE 1/4 Sec. 33 T. 22 N/S R. 54 E. Eureka County
 PERMIT NO. 29895

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Test <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	5. TYPE WELL Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Other <input type="checkbox"/>
--	--	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		1	5	
Sandy clay		5	20	
Sand		20	25	
Clay & Sandy clay		25	63	
Hard sand & gravel		63	66	
Clay & Sand		66	110	
Hard Sand & gravel		110	115	
Sandy Clay		115	132	
Sand Stone		132	146	
Sandy Clay & Clay		146	174	
Cemented S&G		174	178	
Sand & Gravel		178	185	
Clay & Gravel		185	210	
Cemented S&G		210	215	
Sand & Gravel		215	220	
Cemented S&G		220	225	
Sand & Gravel		225	230	
Cemented S&G		230	270	
Gravel & Clay		270	285	
Large Gravel		285	290	
Cemented S&G		290	300	

8. WELL CONSTRUCTION
 Diameter hole 18" inches Total depth 300 feet
 Casing record _____
 Weight per foot _____ Thickness 3/4"

Diameter	From	To	feet	feet
<u>16"</u>	<u>0</u>	<u>300</u>	<u>300</u>	<u>300</u>
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 300 feet
 Perforations: 3/16 x 24 machine slot
 Type perforation 480-2-300
 Size perforation _____
 From 180 feet to 200 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 28 ft. Feet below land surface
 Flow _____ G.P.M.
 Water temperature cool ° F. Quality good

Date started March 19 77
 Date completed April 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>2800</u>	<u>40</u>	<u>24</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim Schooler
 Address Box 833 Ely, Nev. 89310
 Nevada contractor's license number 545 9557
 Nevada driller's license number 515
 Signed _____
 Date 4-10-77