

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Dutton ADDRESS 22301 Wynn Dottle St  
Canyon Park, CA 91303

2. LOCATION N.E. 1/4 SE 1/4 Sec T. 14 N/S R. 19 E. Douglas County  
 PERMIT NO. 3668 CINDY TRAIL - JACKS VALLEY

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G.		0	150	150
SAND & GRAVEL	X	150	184	34
SANDY CLAY		184	188	4

8. WELL CONSTRUCTION  
 Diameter hole 12" 138" 8" inches Total depth 188 feet  
 Casing record 8 5/8  
 Weight per foot 16.9 Thickness 188  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>188</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Footwall  
 Size perforation 2 x 3/32  
 From 16.4 feet to 184 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5/2/77, 19\_\_\_\_  
 Date completed 5/16/77, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 168 feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 146 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.M. Blain  
 Address P.O. 353 Dayton NV 189403  
 Nevada contractor's license number 10950  
 Nevada driller's license number 301  
 Signed William E. Blain  
 Date 5/24/77