

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER PETE RASNER ADDRESS 2115 Utah St
CC, NV 89701

2. LOCATION 1/4 1/4 Sec. 28 T. 15 N/S R 20 E. CC County
 PERMIT NO. 3000 Block Contri Dr

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY SOIL		0	4	4
SOIL		4	7	3
SANDY CLAY		7	42	35
SOIL		42	45	3
SANDY CLAY		45	180	135
GRAVEL	+	180	183	3
SANDY CLAY		183	200	17

WELL CONSTRUCTION

Diameter hole 12 1/2" inches Total depth 200 feet
 Casing record 150 = 8 1/2"
 Weight per foot 16.9 Thickness 188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CONCRETE
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory
 Size perforation 3 x 3/32
 From 180 feet to 196 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 134 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

Date started 4/21/77, 19_____
 Date completed 4/24/77, 19_____
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.M. Blain
 Address Box 353 Dayton, Nev
 Nevada contractor's license number 10950
 Nevada driller's license number 301
 Signed William Blain
 Date 5/24/77

BAILER TEST
 G.P.M. 39 gpm Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours