WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16541
Permit No.
Basin

1. OWNER Virginia Bowden ADDRESS Box 1271, Carson City, Nev.
Pinenut Estates

2. LOCATION ¼ ¼ Sec. 27 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. ~~Lot 170 unit 3~~ Lot 7 Pinenut Estates Unit #1
TA JUL 89 HR

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fill dirt		0	16	16
sandy dirt		16	20	4
Brown clay		20	38	18
dirt & gravel		38	68	30
Brown clay		68	72	4
cementant gravel		72	74	2
sandy clay		74	80	6
sand & gravel wet		80	123	43
Brown clay		123	125	2

Date started 3-14-77, 19
Date completed 3-17-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 12"=50' WELL CONSTRUCTION
Diameter hole 8"=75 inches Total depth 125 feet
Casing record 8 5/8
Weight per foot 16.5 Thickness .188 wall

Diameter	From	To
8 inches	0 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 8/32
From 103 feet to 123 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 Feet below land surface
Flow G.P.M. 20
Water temperature °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Warren W. Labrum
Address P.O. Box 543, Dayton, Nev.
Nevada contractor's license number 14026
Nevada driller's license number 717
Signed Warren W. Labrum
Date March 18, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471