

Log No. 16612
 Permit No.
 Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr. Terry Lish ADDRESS 1241 Patrick Avenue
Reno, Nevada 89502

2. LOCATION 1/4 Sec. 35 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. 6035 Wintergreen Circle Mt. Rose - GALINA TERRACE ESTATES

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Brown clay boulders & some brown decomposed granite sand		0	25	25
Gray brown & white boulders w/ some fine gray sands		25	45	20
Gray brown & white boulders w/ fine gray sand formations about the same		45	65	20
Gray brown & white boulders w/ fine gray & brown sands		65	85	20
Gray brown & white boulders w/ more fine gray & brown sands		85	110	25
Gray brown & white boulders w/ fine gray & brown sand		110	165	55
Gray brown & white boulders w/ fine gray & brown sand and some brown clay		165	202	37

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 202 feet
 Casing record 0 - 202' x 6.5/800
 Weight per foot 12.89 Thickness 1.88

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>202</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type transit mix
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from feet to feet

Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 x 2 1/2"
 From 17.8 feet to 202 feet
 From feet to feet

Date started 5-31-77, 19.....
 Date completed 5-31-77, 19.....

7. WELL TEST DATA			
Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	14 GPM @	185' depth	

9. WATER LEVEL

Static water level 150 Feet below land surface
 Flow..... G.P.M.
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed Tony Betita by W.L. McDonald
 Date 1 June, 1977

BAILER TEST

G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours