

Log No. 16612  
 Permit No. \_\_\_\_\_  
 Basin. 80

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Brian Hatoff ADDRESS 716 N. Peters  
Carson City, Nevada 89701

2. LOCATION SW 1/4 SE 1/4 Sec. 34 T. 18N N/S R. 19E Washoe County  
 PERMIT NO. Mt. Rose

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil & brown decomposed granite sand		0	10	10
Brown clay large boulders & cobbles		10	55	45
Gray decomposed granite sand & granite boulders		55	65	10
Big boulder		65	68	3
White granite w/ black spots & some red rock		68	75	7
Broken up red & gray rock		75	85	10
Brown sands w/ red rock & 40% brown clay		85	115	30
Gray & white med fine rounded sands		115	135	20
Gray sand fine to coarse w/ some gravels up to 1/2" in size		135	170	35
Water Zone				

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 170 feet  
 Casing record 0 - 170' x 6 5/8OD  
 Weight per foot 12.89 Thickness 1.88

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>170</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type transit mix  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation factory mill slot  
 Size perforation 1/8 x 2 1/2"  
 From 146 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-23-77, 19\_\_\_\_\_  
 Date completed 5-25-77, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	14 GPM @	165' depth	
	10 GPM @	150' depth	

9. WATER LEVEL  
 Static water level 110 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.  
 Address P.O. Box 404; Sparks, NV 89431  
 Nevada contractor's license number 9767  
 Nevada driller's license number 805  
 Signed Tony Betita by W.L. McDonald  
 Date \_\_\_\_\_  
31 May, 1977

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours