

Log No. 15625
Permit No. _____
Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Hank Everett ADDRESS 270 Parr Blvd.
Reno, Nevada 89502

2. LOCATION 1/4 Sec. 3 T. 20N N/S R. 19 E Washoe County
PERMIT NO. Lot #22 Tamra - Golden Valley

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Decomposed granite sand & clay		0	10	10
Decomposed granite sand some rounded		10	30	20
Decomposed granite sand & clay		30	55	25
Light decomposed granite sand		55	65	10
Decomposed granite sand & clay		65	90	25
Light granite or decomposed granite sand		90	100	10
Granite or decomposed granite sand		100	125	25
Light granite light green in color chips are up to 1/2" in size		125	180	55
Fracture zone darker green rock granite		180	185	5
Hard green granite very few fractures		185	195	10
Fracture area very broken up picking up water 5' in thickness w/ 5-10' of hard granite & then more broken zones		195	226	31
Test Hole: Hard gray granite		226	242	16

Date started 6-21-77, 19_____
Date completed 6-24-77, 19_____

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 226 feet
Casing record 0 - 226' x 6 5/8 OD
Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>1.0</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>226</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type transit mix
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 x 2 1/2"
From 20.2 feet to 226 feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 195' Feet below land surface
Flow _____ G.P.M.
Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co. Inc.
Address P.O. Box 404
Nevada contractor's license number 9767
Nevada driller's license number 805

Signed Tony Betita by W.L. McDonald
Date 27 June, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	12 GPM @	225' depth	

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours