

Intent card mailed
 OFFICE USE ONLY
 Log No. 16702
 Permit No. _____
 Basin. 092B

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Michaelson Construction Inc. ADDRESS P.O. Box 13381 Reno, Nev. 89507
11745 Cypress St. Lemmon Valley
Lot 9 Block 9 Heppner Subdivision #6

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 15 T. 21 N/S R. 19 E. Washoe County
 PERMIT NO. _____

3.	TYPE OF WORK			4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Other <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>		Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>			Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>			

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy top soil		0	4'	
Hard pan		4'	13'	
Sandy Br. clay		13'	155'	
Sandy Br. clay with sand & gravel streaks		155'	181'	
		155'		

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 181' feet
 Casing record _____
 Weight per foot _____ Thickness 188W

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>181</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to 181 feet
 Perforations:
 Type perforation Factory
 Size perforation 1/8 by 3"
 From 121 feet to 181 feet
 From _____ feet to _____ feet

Date started June 21, 19 77
 Date completed June 26, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. <u>6+</u>	Draw down _____ feet	<u>4</u> hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 100 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Burroughs of Nevada
 Name H. Wayne Burroughs
10310 Old Virginia City Rd.
Reno, Nevada 89511
 Address _____
 Nevada contractor's license number 5092
 Nevada driller's license number 787
 Signed [Signature]
 Date June 13, 1977