DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 7
Permit No.
Basin

1. OWNER BEVERLY WIGHT ADDRESS 327 CHENEY RENO, NEVADA 89502

1.4 acres in the SE corner of SE¼ of NE¼ (south of Placerville Road)

2. LOCATION SE ¼ NE ¼ Sec. 13 T. 21 N/S R. 18 E. WASHOE County

PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface clay		0	19	19
coarse sand		19	24	5
~~sikt sand~~ brown clay		24	88	64
coarse sand		88	117	29
brown clay		117	141	24
coarse sand	X	141	201	60
clay		201	208	7

Date started April, 19 72
Date completed July, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 14 approx Draw down 140 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12¼ inches Total depth 208 feet
Casing record 8 5/8" od
Weight per foot 15.52 Thickness 177 wall

Diameter	From	To
12¼ inches	surface feet	208 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 208 feet

Perforations:
Type perforation MILL SLOTS
Size perforation 1/8" x 3"
From 148 feet to 208 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 94 Feet below land surface
Flow G.P.M. 20
Water temperature 58 °F. Quality very good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY

Address 1500 RANGER ROAD RENO, NV 89506

Nevada contractor's license number 7462A

Nevada driller's license number 615

Signed W. L. Boyd

Date July 26, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471