DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

APN 86-250-52 73

OFFICE USE ONLY
Log No. 16772
Permit No.
Basin 92A - LEMMON-WEST

1. OWNER HOWARD TOMPKINS ADDRESS 237 EAST 7th Street RENO, NV

SE CORNER O'SAGE & PLACERVILLE ROADS - Silver Knolls area

2. LOCATION SE ¼ NE ¼ Sec. 13 T. 21 N/S R. 18 E. WASHOE County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface clay		0	18	18
coarse sand		18	27	9
brown clay		27	83	56
coarse sand		83	121	44
brown clay		121	147	26
coarse sand	X	147	194	47
clay		194	200	6

Date started April, 19 72
Date completed July, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 14 approx Draw down 140 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 200 feet
Casing record 8 5/8" od
Weight per foot 15.52 Thickness .177

Diameter	From	To
12¼ inches	surface feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation MILL SLOTS
Size perforation 1/8 x 3"
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 102 Feet below land surface
Flow G.P.M. 20
Water temperature 58 ° F. Quality very good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY

Address 1500 RANGER ROAD RENO, NV 89506

Nevada contractor's license number 7462 A

Nevada driller's license number 615

Signed [illegible]

Date JULY 27, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471