

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert & Sherry Barnett ADDRESS Yardville Nevada
 2. LOCATION Block C, E. 1/4 Sec. 26 T. 13 N/S R. 20 E. Douglas County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt & Broken Rock		0	3	3
Brickdust Clay		3	50	47
Lower Sand & Clay		50	90	40
Gravel & Clay - Cobble		90	128	38
Water at 52 feet				

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 128 feet
 Casing record 8 3/8" C.O.
 Weight per foot 19 Thickness 188
 Diameter From To
8 3/8 inches 0 feet 12.8 feet
 inches feet feet
 Surface seal: Yes No Type Cement
 Depth of seal feet
 Gravel packed: Yes No
 Gravel packed from feet to feet
 Perforations:
 Type perforation factory
 Size perforation 1/8"
 From 12.8 feet to 12.8 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started Aug 14 19 77
 Date completed Aug 17 19 77

9. WATER LEVEL
 Static water level 7.5 Feet below land surface
 Flow G.P.M.
 Water temperature 68 ° F. Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Arthur W. Graham
 Address Yardville, Nevada
 Nevada contractor's license number 10953
 Nevada driller's license number 1751
 Signed A. W. Graham
 Date Aug 18, 1977

BAILER TEST
 G.P.M. 30 Draw down 0 feet 2 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours