



Log No. 16812
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Landmark Development Co., ADDRESS 2745 Sherwood Place
 Reno, Nevada

2. LOCATION NE 1/4 NE 1/4 Sec. 9 T. 17N N/S R. 19 E. Washoe County
 PERMIT NO. Lot 304

3. TYPE OF WORK
 New Well Recondition
 Deepen Other TEST HOLE

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy top soil w/ boulders mixed-some clay		0	10	10
Coarse sands w/ some boulders		10	26	16
Fine to coarse sand-some yellow clay mixed some clean streaks & loose		26	45	19
Fine silty sands-2% coarse		45	55	10
Fine to coarse sands-appears to be granetic in nature. occasional clay zones 70-80.				
Coarser zone 110-115		55	125	70
WATER ZONES				
20 - 30				
65 - 70				
90 - 95				
110 - 115 Major Aquifer				

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 125 feet
 Casing record 0
 Weight per foot Thickness

Diameter	From	To
inches	feet	feet

Surface seal: Yes No Type
 Depth of seal feet
 Gravel packed: Yes No
 Gravel packed from feet to feet

Perforations:
 Type perforation
 Size perforation
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started 8-9-77, 19.....
 Date completed 8-10-77, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN;	15 GPM @	125' depth	

9. WATER LEVEL

Static water level 2 Feet below land surface
 Flow G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 923 & 817

BAILER TEST

G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

Signed *W.L. McDonald*
 Mondragon & Padilla by: W.L. McDonald
 Date 31 August, 1977