

Log No. 16922
 Permit No. _____
 Basin. _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Landmark Development Co. ADDRESS 2745 Sherwood Place
Reno, Nevada

2. LOCATION 1/4 Sec. 10 T. 17 N/S R. 19 E. Washoe County
 PERMIT NO. Lot 61

3. TYPE OF WORK
 New Well Recondition
 Deepen Other **TEST HOLE**

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Gray boulder-broken-some sand		1	5	4
Brown clayey sands some gravels 40 - 50'		5	85	80
Small gravels to 3/4" diameter w/ fine to coarse sands mixed, some brown clay occasionally mixed silty at times		85	211	126
Black broken rock (like gravel) w/ brown sand areas & mixed		211	305	94
Black broken rock-occasional clay mixed-harder as depth increases		305	375	70
WATER ZONES				
110 - 140	1 GPM			
260 - 300	2-4 GPM			
315 - 375	18 GPM Total			

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 375 feet
 Casing record _____
 Weight per foot _____ Thickness _____

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 8-10-77, 19____
 Date completed 8-11-77, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	18 GPM @	370' depth	

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 265 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 923 & 817
 Signed Mondragon Padilla by W.L. McDonald
 Mondragon & Padilla by: W.L. McDonald
 Date 31 August, 1977