DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 7682
Permit No.
Basin

1. OWNER James Hines ADDRESS 7510 Belmont Golden Valley

2. LOCATION ¼ ¼ Sec. 10 T. 22 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil & clay | | 0 | 2 | 2 |
| Clay & D.G. | | 2 | 19 | 17 |
| Cemented D.G. | | 19 | 91 | 72 |
| Broken rock | yes | 91 | 94 | 3 |
| Granite hard | | 94 | 111 | 17 |
| Broken granite | yes | 111 | 116 | 5 |
| Granite hard | | 116 | 120 | 4 |
| D.G. soft | yes | 120 | 125 | 5 |
| D.G. & clay | | 125 | 153 | 28 |
| D.G. & gravel | yes | 153 | 161 | 8 |
| Granite hard | | 161 | 162 | 1 |

Date started July 19 77
Date completed Aug. 19 77

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| NO Test | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. No Test Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 50 feet
Casing record 6 inch 162
Weight per foot Thickness .156

| Diameter | | From | | To | |
|---|---|---|---|---|---|
| 6 | inches | 0 | feet | 118 | feet |
| 5 | inches | 118 | feet | 162 | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |
| | inches | | feet | | feet |

Surface seal: Yes [X] No [ ] Type Cemnet
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 118 feet

Perforations:
Type perforation Factory
Size perforation 1/8 X 3
From 162 feet to 78 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Glenn Pump & Drilling Co.
Address P.O. Box 99 Steamboat, Nev.
Nevada contractor's license number 11139
Nevada driller's license number 698
Signed J. M. Glenn
Date Aug 17, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471

1977 SEP 12 AM 10:18