

1 of 2

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Jason Corporation ADDRESS 86 Butte Way
Yerington, Nevada
SARAD 1
 2. LOCATION N0 1/4 NE 1/4 Sec. 5 T. 14 N R. 2 E Lyon County
 PERMIT NO. 5

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other R.C.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Auger, Brown Clay				
streaks of Limestone		0	20	20
Brown Clay		20	30	10
Cemented Gravel&Sand		30	40	10
Sand & Gravel		40	47	7
Gray Clay		47	50	3
Sand & Gravel		50	62	12
Brown Clay&Sand		62	100	38
Brown Clay		100	117	17
Sand & Gravel		117	132	15
Sand, Gravel & Clay		132	142	10
Gravel		142	150	8
Blue Clay		150	160	10
Hard Blue Clay		160	180	20
Sand & Gravel		180	200	20
Sand, Gravel & Clay		200	220	20
Sand & Gravel		220	240	20
Fine Blue Sand		240	245	5
Gravel&Blue Sand		245	252	7
Brown Clay		252	260	8
Brown Clay&Gravel		260	270	10
Brown Clay		270	280	10
Gravel, some Clay		280	287	7
Gravel & Sand		287	296	9
Sand, Gravel, Gr. Clay		296	300	4
Gray Clay		300	312	12
Brown Clay		312	320	8

8. WELL CONSTRUCTION
 Diameter hole 28 inches Total depth 500 feet
 Casing record
 Weight per foot 42# Thickness 250"

Diameter	From	To
<u>16</u> inches	<u>+1</u> feet	<u>500</u> feet
.....
.....
.....
.....
.....
.....

 Surface seal: Yes No Type.....
 Depth of seal..... feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 500 feet
 Perforations:
 Type perforation Saw Cut
 Size perforation 1/8" x 3" Double Cut
 From 160 feet to 500 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started August 19, 1977
 Date completed August 21, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

DEVELOPED BAILER TEST BY AIR
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours

9. WATER LEVEL
 Static water level 25 Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thompson Drilling Co., Inc.
 Address 3215 Cinder Lane-Las Vegas, Nev.
 Nevada contractor's license number 4286A
 Nevada driller's license number 581
 Signed Patrick V. Thompson
 Date September 10, 1977

