WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16912
Permit No.
Basin

1. OWNER JACK C. KELLY ADDRESS 975 RYLAND AVE
RENO -
LOT 1 - NORTH POINT SUBDIV. GOLDEN VALLEY -

2. LOCATION ¼ ¼ Sec. 11 T. 20 N/S R. 19 E. WASHOE County
PERMIT NO. DOMESTIC

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒ AIR
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	
DG- SOFT		2	41	
DG HARD		41	55	
GRANITE		55	230	
WATER IN FRACTURED IN GRANITE	X	185		
FRACTURE			to 230'	

Date started 8-16, 1977
Date completed 8-18, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

X

BAILER TEST
G.P.M. 30 GR JET Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 230 feet
Casing record 230' - 6 5/8
Weight per foot ..... Thickness .219

Diameter	From	To
6 5/8 inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 230 feet

Perforations:
Type perforation MILL SLOT
Size perforation 5/32 x 3"
From 180 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160' Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BURT DRILLING
Address Box 11324 Reno
Nevada contractor's license number 6589
Nevada driller's license number 899
Signed [signature]
Date 8-19-77

USE ADDITIONAL SHEETS IF NECESSARY

5471